

# Aadhi Engineers

Grade 'A' Electrical Contractor

No.59-Bethani Nagar,  
Vilachery Road, Pasumalai Post,  
Madurai-625 004.  
Whatsapp No.: 97865 70443  
Cell No. : 9443370443,9443925703  
E-Mail:aadhiengineers@yahoo.com

Date: 25.05.2023

To  
M/s.BHARATIYA VIDYA BHAVAN'S GANDI VIDYASHRAM,  
Post Box No.9, Golf Club Road,  
Kodaikanal - 624 101.

Sub : Electrical Inspection - Checking - Report - Submission - Reg.

Ref : Electrical installation & TNEB SC NO as follow.

TNEB SC No. 05 - 252 - 004 - 52; School Class Room Buildings;

TNEB SC No. 05 - 252 - 004 - 907; New Boys Hostel building.

TNEB SC No. 05 - 252 - 004 - 141; Girls Hostel building;

TNEB SC No. 05 - 252 - 004 - 158; Dining Hall & Kitchen;

\* \* \* \* \*

With reference to the above, we have inspected the above premises electrical installations on 22.05.2023 and observed following found satisfactory.

01. All the light points and switch boards.
02. All the Fan points and switch boards.
03. All the plug points, switch controls & Earthing of sockets
04. All the Earth pits and the values are as per norms.
05. LDBs & PDBs end terminations checked OK.

Checked By  
Er.P.BALASARAVANAN,  
C License No.53859;  
( Valid Upto 17.06.2026 )

For Aadhi Engineers



Proprietor (S.SANKARAVEL)

EA Licence No. 1979

Dated 30-11-1999

Valid up to 11/8/2023.



Dr. Meera Rajkumar  
4/7/23

Principal

Bhavan's Gandhi Vidyashram

Kodaikanal - 624 101

Administrative Officer

Bhavan's Gandhi Vidyashram  
Kodaikanal.



ந.க.எண் 261/v/2023

தீயணைப்பு (ம) மீட்புப் பணிகள் நிலையம்

வ.எண் :- 24/2023

கொடைக்கானல்

நாள் :-03/06/2023

### தடையின்மைச் சான்று

பொருள் :- தீயணைப்பு - மீட்புப் பணிகள் துறை. கொடைக்கானல் தீயணைப்பு (ம)

மீட்புப் பணிகள் நிலையம், பள்ளிக்கூடத்திற்கு தீ உரிமம் வழங்கிட  
தடையின்மைச் சான்று வழங்குதல் - குறித்து

அரசு ஆணை எண்.122 பள்ளிக்கல்வி (2) துறை நாள்: 14.09.2004

அரசு ஆணை எண்.123 பள்ளிக்கல்வி (2) துறை நாள்: 14.09.2004

3) தலைமையாசிரியர் 'பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம்

பாம்பாள்புரம் கொடைக்கானல்

என்பவரிடமிருந்து பெறப்பட்ட விண்ணப்பம் நாள்: 03/06/2023

பார்வையில் காணும் அரசினர் ஆணை மற்றும் விண்ணப்பத்தின்படி

கதவு இலக்கம் 15/16\_கோல்ப் கிளப் ரோடு பாம்பாள்புரம் கொடைக்கானல் என்ற  
முகவரியில் நிறுவப்பட்டுள்ள பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம் .மேல்நிலைப்

பள்ளியினை 03/06/2023 அன்று நிலைய அலுவலர் ஆ.அன்பழகன் என்பவரால் ஆய்வு  
செய்யப்பட்டது. இவ்விடத்தில் உள்ள பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தீயணைப்புமீட்புப்  
பணிகள் நோக்கிலிருந்து யாதொரு தடையும் இல்லை.

இத்தடையின்மை சான்று வழங்கிய தேதியில் இருந்து ஒரு வருட காலத்திற்கு  
மட்டும் செல்லதக்கது

பெறுநர்.

தலைமையாசிரியர்,

'பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம்

.மேல்நிலைப்பள்ளி பாம்பாள்புரம் கொடைக்கானல்

நிலைய அலுவலர்  
தீயணைப்பு (ம) மீட்புப் பணிகள் நிலையம்  
கொடைக்கானல் - 624 101  
திண்டுக்கல் மாவட்டம்

நகல். மாவட்ட அலுவலர் திண்டுக்கல் மாவட்டம்

Dr. Meera Rajkumar  
4/7/23  
Principal

Bhavan's Gandhi Vidyashram  
Kodikkal - 624 101

Administrative Officer  
Bhavan's Gandhi Vidyashram  
Kodikkal



**TAMIL NADU FIRE - RESCUE SERVICES**  
**FIRE SERVICE LICENCE**

(Under Section 13 of the Tamil Nadu Fire Service Act 1985  
and with Tamil Nadu Service Rules 1990-Appendix-III)

Licence No: 553/2023

K.Dis No: 7224/C1/2023

Date: 26.06.2023

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985 for **HOSTEL** within the jurisdiction of **DINDIGUL DISTRICT** in the name of **M/S. BHARATIYA VIDYA BHAVAN'S GANDHI VIDYASHRAM** at the premises **T.NO: 4,5/1,8, BLOCK NO: 15,16, WARD NO: B, GOLF CLUB ROAD, KODAIKANAL, DINDIGUL DISTRICT**. Subject to the condition noted thereon and such other conditions as may be prescribed.


**THE ABOVE PREMISES INSPECTED BY MR. A.ANBALAGAN - STATION OFFICER KODAIKANAL ON : 19.06.2023**

**CONDITIONS**

As per Col.13 of Appendix V to the Rules under section 13 of the Act

1. This Licence is valid for one year from the date of issue.
2. Regular Licence has to be obtained from the competent authority.
3. Fire & Life Safety Systems / arrangements have to be provided in accordance with the Requirements of NBC of India 2016 Part IV Fire & Life Safety.
4. Transparent fire retardant coating should be in all Electrical termination panels.
5. All the Fire Safety Equipments / Systems provided in the premises should be given periodical care and maintenance.
6. If there is any deviation from the Govt. Rule and Act the Licence issued will stand Cancelled.
7. Mock Drill should be conducted atleast once in 6 months.
8. Fire Fighting trained employee / must be available in the premises to Operate the Equipments / Systems.
9. If any extension or alteration or change of business is made in the existing building, then the applicant should apply and get separate permission.

(Office Seal with Date)



*[Signature]*  
District Officer  
Fire and Rescue Service,  
Dindigul District,  
Dindigul. *26/6/2023*

**M/S. BHARATIYA VIDYA BHAVAN'S GANDHI VIDYASHRAM,**

**POST BOX NO: 9,**

**GOLF CLUB ROAD,**

**KODAIKANAL TALUK,**

**DINDIGUL DISTRICT.**

*Ahankarav*  
Administrative Officer  
Bhavan's Gandhi Vidyashram  
Kodaikanal

*Dr. Teena Rajkumar*  
Principal  
4/7/23  
Bhavan's Gandhi Vidyashram  
Kodaikanal - 624 101

Copy To: Joint Director, Fire and Rescue Service, Western Region, Coimbatore-18.