

# TAMIL NADU FIRE - RESCUE SERVICES

## FIRE SERVICE LICENCE

(Under Section 13 of the Tamil Nadu Fire Service Act 1985  
and with Tamil Nadu Service Rules 1990-Appendix-III)

Licence No: 665/2024  
K.Dis No: 8771/C1/2024

Date: 06.08.2024

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985 for HOSTEL within the jurisdiction of DINDIGUL DISTRICT in the name of M/S.BHARATIYA VIDYA BHAVAN'S GANDHI VIDYASHRAM, at the premises T.S.NO: 4,5/1,8, BLOCK NO: 15,16, WARD NO:B, GOLF CLUB ROAD, KODAIKANAL, DINDIGUL DISTRICT. Subject to the condition noted thereon and such other conditions as may be prescribed.

THE ABOVE PREMISES INSPECTED BY MR. P.GOPAL.- STATIO OFFICER- KODAIKANAL  
ON: 26.07.2024.


### CONDITIONS

As per Col.13 of Appendix V to the Rules under section 13 of the Act

1. This Licence is valid for one year from the date of issue.
2. Regular Licence has to be obtained from the competent authority.
3. Fire & Life Safety Systems / arrangements have to be provided in accordance with the Requirements of NBC of India 2016 Part IV Fire & Life Safety.
4. Transparent fire retardant coating should be in all Electrical termination panels.
5. All the Fire Safety Equipments / Systems provided in the premises should be given periodical care and maintenance.
6. If here is any deviation from the Govt. Rule and Act the Licence issued will stand Cancelled.
7. Mock Drill should be conducted atleast once in 6 months.
8. Fire Fighting trained employee / must be available in the premises to Operate the Equipments / Systems.
9. If any extension or alteration or change of business is made in the existing building, then the applicant should apply and get separate permission.

(Office Seal with Date)



  
District Officer  
Fire and Rescue Service,  
Dindigul District,  
Dindigul. 6.8.24

To :

M/S.BHARATIYA VIDYA BHAVAN'S GANDHI VIDYASHRAM,  
POST BOX NO:9,  
GOLF CLUB ROAD,  
KODAIKANAL,  
DINDIGUL DISTRICT.

ந.க.எண்: 373/v/2024

நாள்: 11-07-2024

வ.எண். : 26/2024

## கொடைக்கானல் தீயணைப்பு - மீட்புப்பணிகள் நிலையம்

### தடையின்மைச் சான்று

பொருள் : தீயணைப்பு - மீட்புப்பணித்துறை, கொடைக்கானல் தீயணைப்பு-மீட்புப்பணிகள் நிலையம். பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தடையின்மைச்சான்று வழங்குதல் - குறித்து.

- பார்வை : 1. அரசு ஆணை எண் - 122 பள்ளிக்கல்வி (2) துறை நாள் 14-09-2004  
2. அரசு ஆணை எண் - 123 பள்ளிக்கல்வி (2) துறை நாள் 14-09-2004  
3. தலைமையாசிரியர், பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம் பாம்பார்புரம், கொடைக்கானல் என்பவரிடமிருந்து பெறப்பட்ட விண்ணப்பம் நாள்: 08-07-2024.

\*\*\*\*\*

பார்வையில் காணும் அரசினர் ஆணை மற்றும் விண்ணப்பத்தின்படி சர்வே எண்: கதவு இலக்கம் 15/6, கோல்ப் கிளப் ரோடு, பாம்பார்புரம், கொடைக்கானல், என்ற முகவரியில் நிறுவப்பட்டுள்ள பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம் மேல்நிலைப்பள்ளியினை 11-07-2024 அன்று நிலைய அலுவலர் க.சக்திவேல் என்பவரால் ஆய்வு செய்யப்பட்டது. இவ்விடத்தில் உள்ள பள்ளிக்கூடத்திற்கு அங்கீகாரம் வழங்கிட தீயணைப்பு - மீட்புப்பணிகள் நோக்கிலிருந்து யாதொரு தடையும் இல்லை எனச்சான்று வழங்கலாகிறது.

தேதியுடன் கடிய முத்திரை



பவான்ஸ் காந்தி வித்யாலயாஸ்ரமம்  
15/6, கோல்ப் கிளப் ரோடு,  
பாம்பார்புரம்,  
கொடைக்கானல்,

நகல் :

1. மாவட்ட அலுவலர், திண்டுக்கல் மாவட்டம்,

  
11/7/2024  
நிலைய அலுவலர்  
தீயணைப்பு (மீட்பு) பணிகள் நிலையம்  
கொடைக்கானல் - 624 101  
திண்டுக்கல் மாவட்டம்